

From: Amanda Falkenhagen <amandaf@rushingco.com>
Sent: Friday, March 11, 2022 10:49 AM
To: DES SBCC <sbcc@des.wa.gov>
Subject: 2021 WSEC Public Comment - Lighting

External Email

Hello,

I would like to submit public review comments for the 2021 WSEC draft as noted below:

Section C405.5.1: Suggest clarifying if the efficacy of 100 lumens/watt is based on initial lumens or delivered lumens.

Section C405.2.8.3: Suggest removing the struck through portion below to provide greater clarity. The current wording is bulky and difficult to interpret.

High end trim. Luminaires subject to high end trim shall be initially configured with the following:

1. Programmed to limit the initial maximum lumen output or maximum lighting power to 85 percent or less of full light output or full power ~~from full output~~ or to meet the target light level documented in project sequence of operations using the least amount of power.

Thank you,

Amanda Falkenhagen

Senior Lighting Designer

LC, MIES, LEED Green Associate

RUSHING

D: 206-452-8014 | O: 206-285-7100

rushingco.com

Office Hours: M TH 8-noon T 1-5pm W 8-5